

Certificate of Compliance



You have been awarded:

Intertek WH US Mark for Category C - Proprietary Frames

Standards: UL 10(c) (2016)

Certificate number: WHI16-29215802

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization: Bin Ghurair Metal Industries L.L.C.

Plot No. 597-400

Dubai Investment Park 2

Dubai

United Arab Emirates

Product: Bin Ghurair 90 Minutes Fire Door Frames

Spec ID: 37721

Fire Rating: 90 Min PP Category C Standard Frame


Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.

Initial registration: November 02, 2016

Date of expiry: December 31, 2024

Issue status: 7

Authorized By: 

Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

FIRE RESISTANT PRODUCTS & COMPONENTS

Category C Frames

PRODUCT COVERED

Fire Door Frames

PRODUCT DESCRIPTION

Steel Fire Door Frames intended for 1-1/2 hr, 1 hr & 3/4 hr locatons for use in masonry constructions.

For use with listed and labeled steel fire doors only.

Maximum Frame Size

Type	Size
Double	2190 mm wide x 2391 mm high
Single	1143 mm wide x 2391 mm high

RATING

The above Door Frame is rated for 90 minutes of fire resistance to the following standards:

UL 10C