# intertek

Total Quality. Assured.



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

### Certificate of Compliance

You have been awarded:

## WH Service Mark 2014 for Category D - Door/frame Assemblies

Standards: BS 476 Part 22 (1987), EN 1634-1 (2014)

Certificate number: WHI17-29215805

**Organization:** Bin Ghurair Metal Industries L.L.C. Plot No. 597-400 Dubai Investment Park 2 Dubai United Arab Emirates

**Product:** Bin Ghurair - EN 1634-1/BS 476 Part 22 - 240 minute Swinging Type Fire Door & Frame Assembly (Rockwool Infill) *Spec ID:* 42147

Fire Rating: 4 Hour Fire Rated Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc. Initial registration: July 31, 2017 Date of expiry: December 31, 2024 Issue status: 8

Authorized By:

Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc. 545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification accordance with the agreement. Intertek assumes no liability or any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirely. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production and do not relieve the Client of their obligations in this respect.

### LISTING INFORMATION

#### FIRE RESISTANT PRODUCT AND COMPONENTS

Fire door and frame assembly - Rockwool infill type

#### PRODUCT COVERED

Single Leaf Steel Fire Door and Frame

#### **PRODUCT DESCRIPTION**

Single swinging, steel stiffened, hollow metal type, Rockwool (80 kg/m<sup>3</sup>) infill fire doors intended for use in masonry constructions.

The door frame can be installed with or without grouting.

Limitations:

Minimum latch throw - 11mm, 19mm (Panic push bar).

Maximum tested sizes:

Single door frame - 1200mm x 2800mm x 150mm (w x h x jamb depth) Single door leaf - 1094mm x 2737mm x 45mm (w x h x thickness)

Vision Panel Glass - 225mm x 725mm x 5mm (w x h x thickness)

Double door: Not allowed

Hardware:

Hinge: Simplex ref: HSSBS-SIM-FR-4x3x3 or HSSBS-SIM-FR2BB443, Fort ref: 450.434 Panic Push Bar: Simplex ref: SED1501S; External Trim: Simplex ref: EDA 108 Mortise Lockset: Simplex ref: DOM D31, Dorma ref: 752-F Lock Cylinder: Simplex ref: 1951 Manual Flush Bolt: Simplex ref: SPX-100, Hager ref: 282D Door closer: Simplex ref: SPX8300, Simplex ref: STS680 - installed on the exposed side

Allowed Extended Sizes for 240 minute fire rating:

	Width (mm)	Height (mm)	Area (sq. m)
		3220 (at 1251mm width)	4.03
Single Door Leaf		3147 (at 1140mm width)	3.59

Allowed Extended Sizes for the vision panel for 240 minute fire rating

	Width (mm)	Height (mm)	Area (sq. m)
Vision panel glass	258	833	0.10
	(at 736mm height)	(at 228mm width)	0.19

Allowed Extended Sizes for 120 minute fire rating:

	Width (mm)	Height (mm)	Area (sq. m)
Single Door Frame		3640 (at 1244mm width)	4.53
Single Door Leaf		3558 (at 1132mm width)	4.03

#### RATINGS

The single leaf door and frame assembly has been evaluated in accordance with EN 1634-1:2014 and BS 476 Part 22 standards and achieved the following ratings:

Integrity	240 Minutes
-----------	-------------