

# Certificate of Compliance



You have been awarded:

## **Intertek WH US Mark for Category D - Door/frame Assemblies**

Standards: UL 10(c) (2016), NFPA 252 (2017)


Certificate number: WHI17-29215807

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

**Organization:** Bin Ghurair Metal Industries L.L.C.  
Plot No. 597-400  
Dubai Investment Park 2  
Dubai  
United Arab Emirates

**Product:** Bin Ghurair - UL 10C - 120 minutes Swinging Type Fire Door & Frame Assembly (Honeycomb Infill)  
*Spec ID:* 42859  
*Fire Rating:* 2 Hour PP Category D Door/Frame Assemblies  
*Listing Information:* See following page(s)

**Certification body:** Intertek Testing Services NA, Inc.  
**Initial registration:** November 21, 2017  
**Date of expiry:** December 31, 2024  
**Issue status:** 8

Authorized By:   
**Jean-Philippe Kayl, Director of Certification**

Intertek Testing Services NA, Inc.  
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA  
Phone: 847-439-5667 Fax: 847-439-7320

[www.intertek.com](http://www.intertek.com)

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

## LISTING INFORMATION

### FIRE RESISTANT PRODUCT AND COMPONENTS

Fire door and frame assembly - Honeycomb infill type

### PRODUCT COVERED

Single Leaf Steel Fire Door and Frame

### PRODUCT DESCRIPTION

Single, hollow metal type, honeycomb infill fire doors intended for use in masonry constructions.

The door frame can be installed with or without grouting.

Limitations:

Minimum latch throw - 19mm (3/4 in).

Maximum sizes:

Single door frame - 1200mm x 3000mm x 150mm (w x h x jamb depth)

Single door leaf - 1094mm x 2937mm x 45mm (w x h x thickness)

Vision panel cut-out size - 288mm x 288mm

Vision panel glass size - 279mm x 279mm x 5mm (w x h x thickness)

### RATINGS

The single leaf door and frame assembly has been evaluated in accordance with UL 10C (2016) standard and achieved the following ratings:

Fire rating - 120 minutes (2 hours)